Applus

Constancy of Performance Certificate

LGAI Technological Center S.A. (APPLUS), Notified Body No. 0370, issues this certificate to:

APPLICANT

Placed on the market under the name of

Normagrup Technology, S.A.

Parque Tecnológico de Asturias. Parcela 10 33420 Llanera (Oviedo) Asturias

Manufactured in production plant:

25/32306230

PRODUCT

Fire detection and fire alarm systems

Fire alarm devices. Sounders

Trade mark: NORMADET Models: NSCI & NSAI, Type A

APPLICABLE REGULATION

Construction Product Regulation (CPR)

In compliance with Regulation (EU) No 305/2011 of the European Parliament and of the Council of 9 March 2011

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standard:

EN 54-3:2001, EN 54-3:2001/A1:2002, EN 54-3:2001/A2:2006

Under system 1 for the performance set out in this certificate are applied and the factory production control conducted by the manufacturer is assessed to ensure the constancu of performance of the construction product.

No. 0370-CPR-1344

Date issued: 01/08/2025 First issue date: 22/06/2012

Follow-up date: before 31/08/2026

The validity of this certificate remains valid as long as the harmonised standard, the construction product, the EVCP methods and the manufacturing conditions at the plant are not significantly modified, unless suspended or withdrawn by the notified product certification body.

This document is not valid without its technical annex; whose number coincides with that of the certificate.



Xavier Ruiz Peña Managing Director Conformity Assessment



LGAI Technological Center S.A. (APPLUS) Notified Bodu No. 0370

Campus UAB. Ronda de la Font del Carme s/n 08193 Bellaterra, Barcelona (Spain)







LGAI Technological Center S.A. (APPLUS) Campus UAB. Ronda de la Font del Carme s/n 08193 Bellaterra, Barcelona (Spain) Technical annex Ed. 3 13/12/2013

0370-CPR-1344

Technical Annex

Annex according to EN 54-3:2001, EN 54-3:2001/A1:2002, EN 54-3:2001/A2:2006

Fire detection and fire alarm systems. Part 3: Fire alarm devices. Sounders

Essential characteristics	Clauses in this European standard	Mandated level(s) or class(es)
Sound level	4.2.	Pass
Frequency and sound pattern	4.3.	Pass
Durability	4.4.	Pass
Construction	4.5.	IP21C – Type A
Marking and data	4.6.	Pass
Reproducibility	5.2.	Pass
Operational performance	5.3.	Pass
Durability	5.4.	Pass
Dry heat (operational)	5.5.	Pass
Dry heat (endurance)	5.6.	NA
Cold (operational)	5.7.	Pass
Damp heat, cyclic (operational)	5.8.	Pass
Damp heat, steady state (endurance)	5.9.	Pass
Damp heat, cyclic (endurance)	5.10.	NA
Sulfur dioxide (SO2) corrosion (endurance)	5.11.	Pass
Shock (operational)	5.12.	Pass
Impact (operational)	5.13.	Pass
Vibration, sinusoidal (operational)	5.14.	Pass
Vibration, sinusoidal (endurance)	5.15.	Pass
Electromagnetic compatibility (EMC), immunity (operational)	5.16.	Pass
Enclosure protection	5.17.	Pass
Attention drawing signal and message broadcast sequences	C.3.1.	NA
Synchronisation (option with requirements)	C.3.2.	NA
General testing	C.4.	NA
Broadcast message performance	C.5.1.	NA
Attention drawing signal/silence/message sequence timing	C.5.2.	NA
Message synchronization testing (option with requirements)	C.5.3.	NA

PASS; NPD = No Performance Determined, NA = Not Apply