



Constancy of Performance Certificate

LGAI Technological Center S.A. (APPLUS), Notified Body No. 0370, issues this certificate to:

APPLICANT

Placed on the market under the name of

Normagrup Technology, S.A.

Parque Tecnológico de Asturias, Parcela 10
33420 Llanera (Oviedo) Asturias

Manufactured in production plant:

25/32306230

PRODUCT

Fixed firefighting systems. Components for gas extinguishing systems. Part 1: requirements and test methods for electrical automatic control and delay devices

Extinguishing module: **NTEXT**

APPLICABLE REGULATION

Construction Product Regulation (CPR)

In compliance with Regulation (EU) No 305/2011 of the European Parliament and of the Council of 9 March 2011

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standard:

EN 12094-1:2003

Under **system 1** for the performance set out in this certificate are applied and the factory production control conducted by the manufacturer is assessed to ensure the constancy of performance of the construction product.

No. 0370-CPR-1374

Date issued: 01/08/2025

First issue date: 20/07/2012

Follow-up date: before 31/08/2026

The validity of this certificate remains valid as long as the harmonised standard, the construction product, the EVCP methods and the manufacturing conditions at the plant are not significantly modified, unless suspended or withdrawn by the notified product certification body.

This document is not valid without its technical annex; whose number coincides with that of the certificate.

Xavier Ruiz Peña
Managing Director
Conformity Assessment

Applus+
certification

LGAI Technological Center S.A. (APPLUS)
Notified Body No. 0370
Campus UAB. Ronda de la Font del Carme s/n
08193 Bellaterra, Barcelona (Spain)



Check the status
of this certificate

Certificate

Technical Annex

Annex according to EN 12094-1:2003

Fixed firefighting systems. Components for gas extinguishing systems. Part 1:
requirements and test methods for electrical automatic control and delay devices

Essential characteristics	Clauses in this European standard	Mandated level(s) or class(es)
Functional requirements	4.	Pass Class A
Design requirements	5.	Pass
Additional design requirements for software controlled for electrical automatic control and delay devices	6.	Pass
Marking	7.	Pass
Documentation	8.	Pass
Performance test	9.1	Pass
Functional tests	9.2.	Pass
Ambiental tests	9.3.	Pass
Damp heat, Cyclic (operational)	9.4.	Class A - NA
SO ₂ corrosion (endurance)	9.5.	Class A - NA

PASS; NPD = No Performance Determined, NA = Not Apply